



ERRATUM : RFP OW-006 2025/26

SUPPLY AND DELIVERY OF RAW WATER PUMP AND TRAILER

With reference to the above-mentioned bid as advertised in the National Treasury e-tender portal and Overberg Water website on 01 August 2025. Please note the following amendments on the specifications section of the tender:

SPECIFICATION

Increase in allowable weight of the pump from 750 kg to 2000

Performance Specification of Raw Water Pump						
Item No.	Specification	Unit	Value	Comply	Not Comply	Deviation
1.1	Deisel Driven Pump					
	Flow (Raw water)	m ³ /hr	450			
	Head	m	40			
	Distance	m	415			
	Inlet pipe Diameter	mm	150≤x≤250			
	Outlet Pipe Diameter	mm	150≤x≤250			
	Warrantee	Years	≥1			
	Weight (the pump alone must weigh less than 2000 kg)	kg	<2000			
	The pump must be self priming					

Kind regards

Zanele Tamarana

DATE: 06/08/2025